

Certificate of constancy of performance

Regulation for Construction Products

Certificate No.: 0200-CPR-05564 version 02

Issued by FORCE Certification A/S - EC-notified body number 0200

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Power, control and communication cables

Product	Intended use	Class	AVCP system
Installation Cable Solarix CAT6 UTP LSOHFR B2ca s1 d1 a1 Part no.: SXXD-6-UTP-LSOHFR-B2ca	Supply of electricity and communication inside buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke	B2 _{ca} -s1a,d1,a1	1+

placed on the market under the name or trade mark of:

INTELEK spol. s r.o.
Ercha Roučky 1291/4
627 00 Brno
Czech Republic

and produced in the manufacturing plant(s):

INTELEK spol. s r.o.
Manufacturing plant 01

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the Annex ZZ of the standard:

EN 50575:2014 + A1:2016

under system 1+ for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 2019-01-03 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by FORCE Certification A/S.

FORCE Certification A/S task No.: 118-37054. Certificate ID No.: 11967.

Date of issue: 2021-12-17
Date of expiry: 2025-01-03



Dennis Andersen
Certification manager

Extracts from this Product Certificate may only be reproduced with a written permission from FORCE Certification A/S
This new version of 0200-CPR-05564 is issued due to extension of validity. The previous certificate is withdrawn.